

		A	(A-B)MIX	B	任意							
風量		700	1,000	300	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000
大気圧	kPa	101.3	101.3	101.3	101.3	101.3	101.3	101.3	101.3	101.3	101.3	101.3
乾球温度		0.2	0.1	0	5	55	55	55	52.6	35	35	40
相対湿度	%	100	100	100	100	87	88	88.3	100	55	55	100
湿球温度		0.2	0.1	0.0	5.0	52.4	52.6	範囲超	52.6	27.2	27.2	40.0
絶対湿度	kg/kg	0.00383	0.00381	0.00377	0.00540	0.09733	0.09863	0.09902	0.09999	0.01960	0.01960	0.04888
絶対湿度	kg/kg	0.00383	0.00381	0.00377	0.00540	0.09733	0.09863	0.09902	0.09999	0.01960	0.01960	0.04888
露点温度		0.18	0.13	0.00	5.02	52.11	52.34	52.41	52.59	24.60	24.60	39.97
水蒸気分圧	kPa	0.62	0.62	0.61	0.87	13.711	13.87	13.92	14.03	3.10	3.10	7.38
エンタルピー	kJ/kg	9.78	9.7	9.44	18.59	308.71	312.08	313.10	312.78	85.50	85.51	166.13
エンタルピー	kcal/kg	2.34	2.3	2.26	4.44	73.75	74.56	74.80	74.72	20.43	20.43	39.69
比重量	kg/m <sup>3</sup>	1.28	1.3	1.28	1.26	0.93	0.93	0.93	0.93	1.11	1.11	1.04
		898.33		385.31								
飽和水蒸気分圧		0.62	0.6	0.61	0.87	15.76	15.76	15.76	14.03	5.63	5.63	7.38
			0.1									
比容積計算		0.78	0.78	0.78	0.79	1.08	1.08	1.08	1.07	0.90	0.90	0.96